

## Article

# Seasonal Efficiency of a Brine-to-Water Heat Pump with Different Control Options according to Ecodesign Standards

Jaime Sieres <sup>1,\*</sup>, Ignacio Ortega <sup>1</sup>, Fernando Cerdeira <sup>1</sup>, Estrella Álvarez <sup>2</sup> and José M. Santos <sup>1</sup>

<sup>1</sup> Área de Máquinas y Motores Térmicos, Escuela de Ingeniería Industrial, University of Vigo, Campus Lagoas-Marcosende, 36310 Vigo, Spain; iortega@uvigo.es (I.O.); nano@uvigo.es (F.C.); josanna@uvigo.es (J.M.S.)

<sup>2</sup> Chemical Engineering Department, Escuela de Ingeniería Industrial, University of Vigo, Campus Lagoas-Marcosende 9, 36310 Vigo, Spain; ealvarez@uvigo.es

\* Correspondence: jsieres@uvigo.es; Tel.: +34-986811997

**Abstract:** The seasonal performance of a heat pump indicates its average performance during the heating and/or cooling season, taking into account the different energy demands and their variability over time. Several European and international regulations and policies related with energy efficiency and the reduction of the carbon footprint of energy related products are affecting the heat pump industry. Among them, the ecodesign regulations impose minimum energy efficiency values for heat pumps, efficiencies that are based on the seasonal coefficient of performance. This work is focused on a domestic brine-to-water heat pump for low-temperature applications. The methodology to determine its seasonal coefficient of performance (SCOP) according to the European standard EN 14825 is explained and evaluated based on experimental results. The impact on the SCOP of using some technology options such as fixed or variable speed compressors, and fixed or variable outlet temperature operation is evaluated. Results show that between the lowest and highest efficient option, the SCOP can be improved by 26%.

**Keywords:** heat pump; seasonal efficiency; SCOP; R410A; experimental results; ecodesign



**Citation:** Sieres, J.; Ortega, I.; Cerdeira, F.; Álvarez, E.; Santos, J.M. Seasonal Efficiency of a Brine-to-Water Heat Pump with Different Control Options according to Ecodesign Standards. *Clean Technol.* **2022**, *4*, 542–554. <https://doi.org/10.3390/cleantechnol4020033>

Academic Editors: José Ramón García-Cascales and Antonio López Gómez

Received: 20 May 2022

Accepted: 6 June 2022

Published: 16 June 2022

**Publisher's Note:** MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.




**Copyright:** © 2022 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

## 1. Introduction

The energy demand in the residential sector represents 28% of the total final energy consumption in the EU (62% of the energy consumption of buildings) [1]. The largest energy consumption is dedicated to heating (almost 64%), followed by domestic hot water production (DHW) (15%) [1]. About 76% of this energy is based on fossil fuels. Heat pumps are highly efficient electrically powered devices that can be used to meet the demand for heating, cooling, and/or DHW production. In addition, they do not produce local emissions and can therefore contribute significantly to increase the energy efficiency of buildings. This, and the foreseeable increase in renewable energies in electricity generation in the EU, suggests a considerable increase in sales of heat pumps, which will ultimately help to reduce the carbon footprint of the building energy sector [2].

The heating requirements in a building or in a space depend largely on the outdoor temperature. Figure 1a shows the typical evolution of the heating power demand or heating load curve of a building or dwelling ( $\dot{Q}_b$ ) as a function of the outdoor temperature ( $T_j$ ). The heating thermal load increases as the outdoor temperature decreases. The slope of this curve depends on several factors such as the level of insulation of the house, the glazed surface, the level of ventilation, etc. The design load ( $\dot{Q}_{design}$ ) is the thermal heating load for the design temperature ( $T_{design}$ ). The temperature designated as  $T_{lim}$  is the temperature above which heating is no longer required.



**Figure 1.** Typical evolution of the building heating load and heat output curve of a heat pump as a function of the outdoor temperature for (a) a heat pump with a fixed speed compressor and (b) a heat pump with a variable speed compressor.

Figure 1a also shows a typical curve of the heat output supplied ( $\dot{Q}_{HP}$ ) by a heat pump with a single fixed speed compressor (on/off operation), as a function of the outdoor temperature. The curve represented in this figure could be a typical one of an air-source heat pump, highly dependent on the temperature of the external environment. In the case of a geothermal heat pump, the slope would be much lower or almost zero since it can be assumed that the ground temperature is practically constant and independent of the outdoor temperature.

In Figure 1a, it can be seen that the curves  $\dot{Q}_{HP}$  and  $\dot{Q}_{design}$  have only one point of intersection. The outdoor temperature corresponding to this point is called the bivalent temperature ( $T_{biv}$ ). When  $T_j < T_{biv}$ , the heating demand cannot be supplied by the heat pump alone and a supplementary system is necessary (for example, an electric heater). On the other hand, when  $T_j > T_{biv}$ , the power supplied by the heat pump is greater than the heating load, so the heat pump will necessarily have to switch into on/off operation to adjust its heating capacity to the heating demand. Finally, Figure 1a also shows that there is an operation limit temperature ( $TOL$ ) below which the heat pump will not function and will not deliver any heating capacity.

Figure 1b shows the situation for a variable speed compressor that can change its rotational speed between the values  $\dot{N}_{min}$  and  $\dot{N}_{max}$ . Two heat pump curves are represented in the figure, one for the maximum compressor speed and another one for the minimum compressor speed. As before, the maximum speed curve intersects the heating demand curve at the bivalent temperature ( $T_{biv}$ ). A second temperature ( $T_{biv^*}$ ) can be defined as the temperature for the point of intersection between the heating demand curve and the heat pump curve for the minimum compressor speed. When  $T_j > T_{biv^*}$ , the power supplied by the heat pump (even with the compressor at the minimum rotational speed) is still greater than the heating load, so cycling (on/off) operation would be required to match the heating load. However, when  $T_{biv} < T_j < T_{biv^*}$ , the heat pump can modulate its capacity to satisfy the heating demand, by varying the compressor speed. Therefore, a heat pump that incorporates a variable speed compressor will probably provide higher seasonal energy efficiencies than a fixed-speed one by reducing the number of on/off cycles, as well as by providing higher COPs at part load.

In addition to the technological evolution from fixed speed to variable speed compressors, many current heat pumps have a weather compensation control that allows the unit to adjust the water flow temperature depending on the outdoor conditions. This is based on the idea that at part load, the supply temperature to the terminal units of the heating system can be lower than at design conditions. Then, for this type of unit, as the outdoor temperature increases and the heating load decreases, the heat pump supplies water at

lower temperature. As a result, the condensing temperature decreases at part load leading to higher COP values.


The seasonal coefficient of performance (SCOP) of a heat pump describes its average performance during the heating and/or cooling season, considering the different energy demands and their variability over time. Many authors have chosen the SCOP as an adequate metric parameter for evaluating the effect of refrigerant drop-in studies [3,4], the effect of the type of compressor used (mono-compressor on/off, multi-compressor, or variable speed compressor) [5–7], the effect of the selected bivalent temperature [5,8], the effect of different control strategies [9], or for CO<sub>2</sub>-emissions and economic analyses of different heating technologies [10].

In Europe, Commission Regulation (EU) No. 831/2013 establishes the ecodesign requirements for space heaters, including heat pumps, which evaluation requires the calculation of their seasonal coefficient of performance (SCOP) [11]. The part load testing conditions and the calculation methods to be applied in order to determine the seasonal coefficient of performance are described in EN 14825:2018 standard [12].

This paper is focused on a brine-to-water heat pump for low-temperature applications. The main components of the unit are a variable-speed Scroll compressor, an electronic expansion valve, and brazed-plate heat exchangers for the indoor (water) and outdoor (brine) heat exchangers. The methodology to determine its seasonal coefficient of performance (SCOP) according to the European standard EN 14825 is explained and evaluated based on experimental results. In order to evaluate the impact of different technological and control options, we present and compare SCOP results operating the heat pump with the compressor at fixed speed (at full speed) and at variable speed, as well as considering that the heat pump has fixed or variable outlet temperature operation.

## 2. Heat Pump Description

Figure 2 shows a schematic representation of the heat pump considered in this work. It is a brine-to-water heat pump; the baseline refrigerant is R410A. Refrigerant R410A has a Global Warming Potential (GWP) of 1925 (AR5), so various lower-GWP alternatives have been proposed in recent years, such as R32, R452B, or R454B. Drop-in performance tests for some of these alternatives were previously evaluated by the authors for selected operating conditions [13]. Future analyses, using the SCOP methodology presented in this paper, will allow a more adequate evaluation of alternative refrigerants.



**Figure 2.** Schematic representation of the heat pump.

The main components of the heat pump are a variable speed Scroll compressor, an electronic expansion valve, and plate heat exchangers for the condenser, evaporator, and desuperheater. The desuperheater may be used for domestic hot water production, though it was not used in this work.

The compressor's drive has a cold plate heat exchanger in order to avoid high internal temperatures. Water is used for cooling the drive and for the condensation process. As shown in Figure 2, of the total flow rate in the water loop (measured by the flowmeter  $V_w$ ), a small fraction is diverted to the drive heat exchanger (measured by the flowmeter  $V_{w,cd}$ ) and the remainder flows through the indoor heat exchanger (condenser). The two water flows are mixed at the outlet of the unit. In the evaporator, a propylene glycol-water mixture ( $PGw$ ) with a concentration of 24% by mass of propylene glycol is used as the heat exchange fluid.

The heat pump was equipped with appropriate instrumentation in order to measure its SCOP. Figure 2 shows the location of some relevant sensors used in the experimental setup and Table 1 summarizes their main characteristics. More details about the experimental setup and the instrumentation can be found in previous works [13,14].

**Table 1.** Types of sensors and accuracies.

Variable	Instrumentation	Accuracy
Water and $PGw$ volumetric flow rate	Electromagnetic flow meter	$\pm 0.2\%$ reading
Water volumetric flow rate (compressor's drive heat exchanger)	Paddle-wheel flow sensor	$\pm(0.1 \text{ L/min} + 2.5\% \text{ reading})$
Water and $PGw$ temperatures	PT 100 Class B 1/10	$\pm 0.06 \text{ K}$
Refrigerant temperatures	PT 100 Class A	$\pm 0.4 \text{ K}$
Refrigerant pressures: points 2–5	Pressure transmitter	$\pm 0.04 \text{ bar}$
Refrigerant pressures: points 6, 7 and 1	Pressure transmitter	$\pm 0.02 \text{ bar}$
Refrigerant mass flow rate	Coriolis flowmeter	$\pm 0.2\%$ reading
Refrigerant density	Coriolis flowmeter	$\pm 5 \text{ kg/m}^3$
Water and $PGw$ pressure drop	Differential pressure	$\pm 0.1\%$ reading
Atmospheric pressure	Digital barometer	$\pm 0.003 \text{ bar}$
Compressor's electrical power	Power transducer	$\pm 0.2\%$ reading
Heat pump auxiliary electrical power	Power transducer	$\pm 0.5\%$ reading

### 3. Basis of SCOP Testing and Calculation

In order to evaluate the seasonal performance of the heat pump, the calculation process established in EN 14825:2018 was followed. This requires testing the heat pump unit at different part load conditions as well as the determination of its energy consumption at different non-active modes of operation, such as thermostat off mode, standby mode, off mode, and crankcase heater mode.

#### 3.1. Declared Heat Output and COP

For any test condition, the declared heat output and  $COP$  of the heat pump was determined in accordance with standards EN 14511-2:2018 [15] and EN 14511-3:2018 [16].

The electrical power input to the heat pump ( $\dot{W}_{HP}$ ) includes the power input for driving the compressor ( $\dot{W}_{comp}$ ), the powers required by the water and  $PGw$  pumps ( $\dot{W}_{p,w}$  and  $\dot{W}_{p,PGw}$ ) for the transport of both fluids through the heat pump unit, and any additional electrical power input ( $\dot{W}_{ad}$ ) required by the heat pump (such as control and safety devices).

$$\dot{W}_{HP} = \dot{W}_{comp} + \dot{W}_{p,w} + \dot{W}_{p,PGw} + \dot{W}_{ad} \quad (1)$$

In this work, the water and  $PGw$  pumps are not integral parts of the heat pump. The pump powers to be included in the effective power consumed by the heat pump are estimated using the following formulae, based on the hydraulic power and the pump efficiency values [16].

$$\dot{W}_{p,w} = \dot{W}_{hyd,w} / \eta_{p,w} \quad (2)$$

$$\dot{W}_{p,PGw} = \dot{W}_{hyd,PGw} / \eta_{p,PGw} \quad (3)$$

In the previous equations, the hydraulic power is determined from the measured liquid flow rate and the measured heat pump-side static pressure difference:

$$\dot{W}_{hyd,w} = \dot{V}_w \Delta P_w \quad (4)$$

$$\dot{W}_{hyd,PGw} = \dot{V}_{PGw} \Delta P_{PGw} \quad (5)$$

For the pump efficiencies, the formula proposed by EN 14511:3:2018 for pumps that are not an integral part of the heat pump unit was used.

$$\eta_p = \frac{0.35744 \dot{W}_{hyd}}{1.7 \dot{W}_{hyd} + 17 \left(1 - e^{-0.3 \dot{W}_{hyd}}\right)} \frac{0.49}{0.23} \quad (6)$$

The heating capacity supplied to the water flow is determined from an energy balance between the water conditions at the inlet and outlet of the heat pump:

$$\dot{Q}_w = \dot{V}_w \rho_w c_{p,w} (T_{w,o} - T_{w,i}) \quad (7)$$

This capacity is corrected for the heat from the circulating pump, according to EN 14511-3:2018,

$$\dot{Q}_{HP} = \dot{Q}_w + \dot{W}_{b,w} (1 - \eta_{b,w}) \quad (8)$$

Finally, the declared coefficient of performance ( $COP_d$ ) is calculated from the net heating power and the effective power input:

$$COP_d = \dot{Q}_{HP} / \dot{W}_{HP} \quad (9)$$

### 3.2. Part-Load COP

The seasonal coefficient of performance (SCOP) describes the heat pump average performance during the heating period. It can be used to evaluate how well a heat pump will behave for a particular heating demand curve.

The combination of the outside temperatures ( $T_j$ ) in a locality and the number of annual hours ( $h_j$ ) in which these temperatures are recorded is known as the temperature period ( $bin_j$ ). The EN 14825 standard defines three reference climate conditions: average 'A', coldest 'C', and warmest 'W', for their corresponding three characteristic reference heating stations in the cities of Strasbourg, Helsinki, and Athens, respectively. Figure 3 shows the number of hours in each bin for each of the three reference climate conditions.




Figure 3. Distribution of outside temperatures for the climate conditions 'A', 'C', and 'W'.

To determine the SCOP of a heat pump in accordance with EN 14825, first the heating demand curve must be determined as a function of the outdoor temperature. The part load factor ( $pl$ ) is the ratio between the heating load at a specific temperature  $T_j$  and the design heating load at the design temperature  $T_{design}$ :

$$pl(T_j) = \dot{Q}_b(T_j) / \dot{Q}_{design} \quad (10)$$

The EN 14825 standard assumes that the part load factor varies linearly with the outside temperature. Then, since the heating load is zero at the heating temperature limit ( $T_{lim}$ ), the demand curve can be determined once the design heating load ( $\dot{Q}_{design}$ ) at the design temperature ( $T_{design}$ ) is established.

$$pl(T_j) = \begin{cases} (T_j - T_{lim}) / (T_{design} - T_{lim}) & \text{if } T_j < T_{lim} \\ 0 & \text{if } T_j \geq T_{lim} \end{cases} \quad (11)$$

If the heat pump is a fixed capacity unit, it will need to perform cycling (on/off) operations to achieve the heating load. In the case of a unit with a variable speed compressor, the unit can modulate its capacity by continuously adjusting the compressor rotational speed within the limits of minimum ( $\dot{N}_{min}$ ) and maximum ( $\dot{N}_{max}$ ) speed of the compressor.

Let us designate as  $\dot{Q}_{HP}(T_j)$  the heating power supplied by the heat pump for the temperature interval ( $T_j$ ) and as  $\dot{Q}_b(T_j)$  the heating load for the same temperature. If  $\dot{Q}_{HP}(T_j) > \dot{Q}_b(T_j)$ , the unit switches to on/off operation to adjust its heating capacity to the heating demand. The capacity ratio ( $CR$ ) is defined as:

$$CR = \dot{Q}_b(T_j) / \dot{Q}_{HP}(T_j) = pl(T_j) \times \dot{Q}_{design} / \dot{Q}_{HP}(T_j) \quad (12)$$

In these cases, a degradation coefficient ( $Cd$ ) must be determined by performing a specific test (or a value of 0.9 might be assumed according to the standard) to determine the energy consumption of the heat pump when the compressor is off. It should be noticed that even when the compressor is off, the heat pump energy consumption is not zero because of the energy used by the heat pump auxiliary devices.

$$Cd = 1 - \dot{W}_{HP,Coff}(T_j) / \dot{W}_{HP}(T_j) \quad (13)$$

The part load  $COP$  for each temperature bin is calculated as:

$$COP_{bin} = COP_d \times \frac{CR}{Cd \times CR + (1 - Cd)} \quad (14)$$

where  $COP_d$  is the declared  $COP$  measured by testing the unit at the required part-load capacity or estimated by interpolation between  $COP$ s measured below and above the required capacity. If the heating load is lower than the minimum capacity of the heat pump, the  $COP_d$  at the minimum capacity is used.

If  $\dot{Q}_{HP}(T_j) \leq \dot{Q}_b(T_j)$ , then it is considered that the heat pump works at full capacity ( $CR = 1$ ) and the  $COP$  corresponding to the temperature period ( $bin_j$ ) is the declared  $COP$  measured or calculated by linear interpolation between the nearest heating load conditions, i.e.,  $COP_{bin} = COP_d$ .

### 3.3. Calculation of SCOP

The SCOP can be calculated from the heating load demand and the results of the heating capacity and  $COP$  of the heat pump for each temperature period.

The annual heating demand for any temperature period ( $bin_j$ ) is obtained from the heat load and the number of hours ( $h_j$ ) for the temperature period:

$$Q_b(T_j) = h_j \times \dot{Q}_b(T_j) \quad (15)$$

The total annual heating demand is calculated as:

$$Q_b = \sum_{j=1}^n h_j \times \dot{Q}_b(T_j) = \dot{Q}_{design} \times \sum_{j=1}^n h_j \times pl(T_j) \quad (16)$$

If for a given temperature interval ( $T_j$ ) the capacity is lower than the heating load, i.e.,  $\dot{Q}_{HP}(T_j) < \dot{Q}_b(T_j)$ , it is assumed that the heat pump capacity is supplemented by an electric backup heater.

$$\dot{W}_{elec,bu}(T_j) = \dot{Q}_b(T_j) - \dot{Q}_{HP}(T_j) \quad (17)$$

Therefore, if for each temperature period ( $bin_j$ ) the heat pump performance is given by  $COP_{bin}(T_j)$ , the annual energy consumed by the heat pump and by any supplementary heaters is calculated as follows:

$$E_{on}(T_j) = h_j \left[ \frac{\dot{Q}_b(T_j) - \dot{W}_{elec,bu}(T_j)}{COP_{bin}(T_j)} + \dot{W}_{elec,bu}(T_j) \right] \quad (18)$$

$$E_{on} = \sum_{j=1}^n h_j \left[ \frac{\dot{Q}_b(T_j) - \dot{W}_{elec,bu}(T_j)}{COP_{bin}(T_j)} + \dot{W}_{elec,bu}(T_j) \right] \quad (19)$$

The seasonal coefficient of performance in active mode ( $SCOP_{on}$ ) is defined as the annual heating demand ( $Q_b$ ) divided by the annual electrical consumption of the heat pump during active mode ( $E_{on}$ ).

$$SCOP_{on} = Q_b / E_{on} \quad (20)$$

The total seasonal coefficient of performance (SCOP) considers the energy consumption in active mode, as well as the energy consumption in operating modes other than active. The energy consumption of the unit during thermostat off, standby, off mode, and crankcase heating modes of operation is estimated as a function of the number of hours for each mode of operation (values given by the EN 14825 standard) and the power consumption of the heat pump unit in each mode (which are measured by specific additional tests).

$$E_{HP} = Q_b / SCOP_{on} + \dot{W}_{HP_{TO}} H_{TO} + \dot{W}_{HP_{SB}} H_{SB} + \dot{W}_{HP_{CK}} H_{CK} + \dot{W}_{HP_{OFF}} H_{OFF} \quad (21)$$

$$SCOP = Q_b / E_{HP} \quad (22)$$

### 3.4. Relation with Ecodesign Requirements

Electrical driven space heaters, such as heat pumps or electric boilers, account for a large share of the total energy demand in the EU. In order to reduce the energy consumption of this (and other) equipment, the EU introduced minimum energy efficiency and energy labelling requirements for space heating devices. The Commission Regulation (EU) N° 813/2013 establishes ecodesign requirements for placing on the market space heater and combination heaters with a rated heat output lower than or equal to 400 kW [11]. The requirements for the space heating efficiency are based on the value of the seasonal space heating efficiency ( $\eta_{s,h}$ ) under average climate conditions. This efficiency is calculated as:

$$\eta_{s,h} = \frac{1}{CC} \times SCOP - F(1) - F(2) \quad (23)$$

where  $CC$  is a conversion coefficient equal to 2.5 that reflects the estimated 40% average EU generation efficiency and  $F(1)$  and  $F(2)$  are correction factors. For brine-to-water heat pumps, the corrections are  $F(1) = 3\%$  and  $F(2) = 5\%$  and account for the contributions of temperature controls and pumps. Therefore, the space heating efficiency of a heat pump depends basically on its SCOP value.

The Regulation (EU) N° 811/2013 introduced an energy labelling scale from A<sup>++</sup> to G for space heaters [17]. The energy efficiency class of a heat pump for space heating is based on the value of its seasonal space heating efficiency ( $\eta_{s,h}$ ).

From 26 September 2017, the minimum requirements for seasonal space heating energy efficiency in the case of heat pumps for low-temperature applications is 125% which corresponds to an energy efficiency class A+ or better.

#### 4. Results and Discussion

A set of experimental tests were performed in order to determine the SCOP of the heat pump following the methodology described in the EN 14825 standard, for brine-to-water heat pumps for low temperature applications. In this paper, the SCOP is only evaluated under the average climate conditions, which are the mandatory ones in European energy labelling regulations [11,17].

Table 2 shows the part load test conditions for the average ‘A’ climate conditions. The reference design temperature for heating is  $T_{design} = -10$  °C and the heating limit temperature is  $T_{lim} = 16$  °C. The heat pump test bench is equipped with variable flow pumps, so for all conditions a temperature variation of 5 K was maintained in the water circuit of the indoor heat exchanger (HEX) and 3 K in the  $PGW$  circuit of the outdoor heat exchanger. In all cases, the tests were performed controlling a degree of superheat at the evaporator outlet of 7 K.

**Table 2.** Space heating test conditions at part-load of a brine-to-liquid heat pump for low-temperature applications under average climate conditions (A).

Test Point	Part Load Ratio (%) <sup>d</sup>	Outdoor HEX Temperatures (°C)	Indoor HEX Fixed Outlet (°C)	Indoor HEX Variable Outlet (°C)
A	$(-7 - T_{lim}) / (T_{design} - T_{lim})$	0/ <sup>b</sup>	<sup>a</sup> /35	<sup>a</sup> /34
B	$(2 - T_{lim}) / (T_{design} - T_{lim})$	0/ <sup>b</sup>	<sup>a</sup> /35	<sup>a</sup> /30
C	$(7 - T_{lim}) / (T_{design} - T_{lim})$	0/ <sup>b</sup>	<sup>a</sup> /35	<sup>a</sup> /27
D	$(12 - T_{lim}) / (T_{design} - T_{lim})$	0/ <sup>b</sup>	<sup>a</sup> /35	<sup>a</sup> /24
E	100	0/ <sup>b</sup>	<sup>a</sup> /35	<sup>a</sup> /35
F	$(T_{biv} - T_{lim}) / (T_{design} - T_{lim})$	0/ <sup>b</sup>	<sup>a</sup> /35	<sup>a</sup> / <sup>c</sup>

<sup>a</sup> With a fixed temperature variation of 5 K between inlet and outlet temperatures for units with variable flow pumps. <sup>b</sup> With a fixed temperature variation of 3 K between inlet and outlet temperatures for units with variable flow pumps. <sup>c</sup> Variable outlet shall be calculated by interpolation from the upper and lower temperatures which are closest to the bivalent temperature. <sup>d</sup>  $T_{lim} = 16$  °C.  $T_{design} = -10$  °C for average climate conditions.

The rated heat output of the heat pump is the declared heat output at the design temperature with the compressor running at maximum speed (i.e.,  $\dot{Q}_{HP, rated} = \dot{Q}_{HP, N_{max}}$ ). A value of  $\dot{Q}_{HP, rated} = 12.5$  kW was obtained testing the unit in accordance to EN 14511-2:2018 and EN 14511-3:2018.

In this work, the bivalent temperature ( $T_{biv}$ ) was selected equal to the design temperature ( $T_{design}$ ). The design heating load is equal to the rated heat output of the heat pump (i.e.,  $\dot{Q}_{design} = \dot{Q}_{HP, rated}$ ) and, consequently, the test conditions E and F in Table 2 are the same. Once the design load was established, the part-load tests A to D were performed for the following four scenarios:


1. The compressor operates at fixed speed (maximum speed). Even though the heat pump has a variable speed compressor, it is tested and its SCOP is evaluated as if it were a fixed speed compressor. Additionally, tests are performed for fixed outlet



temperatures in the indoor heat exchanger. This case is denoted as Cf&Tf (Compressor fixed and Temperature fixed).

2. Same as before but with variable outlet temperature. We denote this case as Cf&Tv.
3. Cv&Tf case which comprises a heat pump unit with variable speed compressor and fixed outlet temperature. The compressor speed is adjusted to achieve the part heating load required at each part-load test condition.
4. Heat pump with a variable speed compressor and variable outlet temperature, designated as Cv&Tv.

Figure 4 shows the heating load curve, and the heat output curve and the  $COP_{bin}$  of the heat pump as a function of the outdoor temperature. Results are shown for the heat pump operating with fixed outlet temperature and with the compressor running at fixed and variable speed (Cf&Tf and Cv&Tf, respectively). In the figure, the points with legends A to F are experimental values at part load conditions. Heat capacities and COP values for other temperature intervals were obtained by interpolation or based on the limiting test conditions (at minimum or maximum compressor speed).




**Figure 4.** Heating load curve, heat capacity curve, and  $COP_{bin}$  of the heat pump as a function of the outdoor temperature for a heat pump with fixed outlet temperature and (a) a fixed speed compressor, (b) a variable speed compressor.

Figure 4a shows the results obtained with the heat pump assuming that the compressor operates at fixed speed. For each part load test condition, the declared heat capacity ( $\dot{Q}_{HP}(T_j)$ ) and the declared coefficient of performance ( $COP_d(T_j)$ ) are constant since the fluid temperatures in the indoor and outdoor heat exchangers do not change and the compressor operates at fixed speed. For outdoor temperatures below  $-10\text{ }^\circ\text{C}$  (point E) the heat pump cannot meet the heating load, but for temperatures above  $-10\text{ }^\circ\text{C}$  the heat pump needs to perform on/off cycles in order to adjust its heat output to the heating load. The bin-specific coefficient of performance ( $COP_{bin}(T_j)$ ) is derived from the declared COP and corrected by the degradation coefficient ( $Cd$ ) that accounts for the heat pump energy consumption when the compressor is off (see Equation (14)). When the outdoor temperature increases, so does the difference between the heating capacity and the heating load, resulting in lower values of the capacity ratio ( $CR$ ) and a higher weight of the degradation coefficient on the  $COP_{bin}$ . As a result, the  $COP_{bin}$  decreases slightly with increasing values of the outdoor temperature, as confirmed in Figure 4a.

Figure 4b shows the results when the compressor operates at variable speed. For outdoor temperatures below  $-10\text{ }^\circ\text{C}$  (point E) the heat pump cannot meet the heating load, whereas for temperatures above  $7\text{ }^\circ\text{C}$  (point C) the power supplied by the heat pump is greater than the heating load, so on/off cycling will be required. Between the outdoor temperatures corresponding to points E and C, the compressor adjusts its rotational speed to adapt its power to the required heating load. With regards to the bin-specific coefficient of performance, it can be seen that for outdoor temperatures below  $-10\text{ }^\circ\text{C}$  (point E) the

value of  $COP_{bin}(T_j)$  is constant; this is explained by the fact that for  $T_j < -10$  °C the heat pump operating conditions and compressor speed do not change. As the outdoor temperature increases from  $-10$  °C (point E) to  $+12$  °C (point D), the compressor rotational speed decreases from its maximum (7000 rpm) to its minimum (1800 rpm) value. The  $COP_d$  first increases with a reduction of the rotational speed when changing from part-load conditions E to B. However, further reductions of the heating load and consequently of the compressor speed produces a decrease of the  $COP_d$  value. For part-load factors below that of point C (35%), the  $COP_{bin}(T_j)$  continues to decrease due to the decrease of  $COP_d$  and the greater impact of the degradation coefficient ( $C_d$ ) because of on/off operation, as stated in Equation (14).

The results for a heat pump with variable outlet temperature with fixed and variable speed compressor operation are shown in Figure 5. Now, when the outdoor temperature increases, the heat pump reduces the supply water temperature as indicated in Table 2. Consequently, the heat pump operates at lower condensation temperatures and with higher COP values.




**Figure 5.** Heating load curve, heat capacity curve, and  $COP_{bin}$  of the heat pump as a function of the outdoor temperature for a heat pump with variable outlet temperature and (a) a fixed speed compressor, (b) a variable speed compressor.

For the fixed compressor speed option (Cf&Tv), as the outdoor temperature increases, the COP of the heat pump increases substantially whereas the heat capacity remains nearly constant. For the variable speed case, a comparison of Figures 4b and 5b show that the variable outlet temperature option (Cv&Tv) is similar to the fixed temperature one (Cv&Tf) in terms of heat output, but it is superior in terms of COP.

Once the heating load and the heat capacity and  $COP_{bin}$  curves of the heat pump are determined, the heat demand and the energy consumed by the heat pump for each bin can be evaluated.

Figure 6 shows the bin hours at each outdoor temperature for the average climate conditions as well as the heat demand and the energy consumption of the heat pump. The results are shown for the four heat pump options considered: Cf&Tf, Cv&Tf, Cf&Tv, and Cv&Tv. For all cases, the heat demand is the same; however, there are differences in the energy consumed by the heat pump. The design temperature under the average climate conditions is  $-10$  °C. As shown in Figure 6, this is the minimum expected temperature, so the number of annual hours for temperature values below  $-10$  °C is zero. As a result, for the situation considered in this work, the heat pump can always satisfy the heating demand and a backup heater is not required. As expected, the energy consumed by the heat pump is reduced when the use of variable speed compressors or variable outlet temperature operation are considered.



**Figure 6.** Heating demand and energy consumption distribution under the average climate season for the four different heat pump options.

By adding all heat ( $Q_b(T_j)$ ) and energy input ( $E_{on}(T_j)$ ) values for each outdoor temperature ( $T_j$ ), the annual heat demand, the annual energy consumption, and the active mode seasonal coefficient of performance ( $SCOP_{on}$ ) can be obtained, using Equations (15)–(20).

In order to obtain the total seasonal coefficient of performance (SCOP), the energy consumption of the unit during compressor off mode, thermostat off mode, standby mode, off mode, and crankcase heater mode were also determined as per EN 14825:2018. The compressor-off mode is required for the calculation of the degradation factor (Cd) when the heat pump heating capacity is greater than the heating load. The results from these tests are collected in Table 3. As shown, when rounded to the nearest integer, the power consumption values measured for each mode of operation were the same for the four heat pump options. It should be clarified that the standard only considers losses associated with the heat pump unit. In a real installation, other energy losses will appear which will depend on various factors related to the heating installation, such as the type of terminal units or the use of buffer tanks for reducing the frequency of on/off cycling.

Once the active and non-active energy consumptions are determined, the SCOP and the seasonal space heating efficiency ( $\eta_{s,h}$ ) can be obtained. Table 4 shows the SCOP and  $\eta_{s,h}$  calculated values for the four heat pump options, as well as the corresponding energy efficiency class according to Regulation (EU) N° 811/2013. As shown in the table below, technical evolutions such as variable speed compressors or weather compensation controls that act on the flow temperature can contribute to important energy efficiency improvements of heat pump units.

**Table 3.** Experimental values of power consumption during modes other than active mode for the four different heat pump options.

Mode	Cf&Tf	Cv&Tf	Cf&Tv	Cv&Tv
Compressor off mode for test D (W) <sup>a</sup>	10	10	10	10
Thermostat off mode (W)	13	13	13	13
Standby mode (W) <sup>a</sup>	10	10	10	10
Off mode (W) <sup>b</sup>	0	0	0	0
Crankcase heater mode (W) <sup>c</sup>	0	0	0	0

<sup>a</sup> Liquid pumps are assumed to be off during this mode of operation. <sup>b</sup> The unit is supposed to be switched off during off mode. <sup>c</sup> The heat pump does not include a crankcase heater device so the energy consumption for this mode of operation is zero.

**Table 4.** SCOP, seasonal space heating efficiency, and energy efficiency class for the four different heat pump options.

Parameter	Cf&Tf	Cv&Tf	Cf&Tv	Cv&Tv
SCOP	3.33	3.66	3.55	4.21
$\eta_{s,h}$	125%	138%	134%	160%
Class	A+	A+	A+	A++

## 5. Conclusions

This paper presents an evaluation and analysis of the seasonal performance of a brine-to-water heat pump according to the EN 14825:2018 standard. The SCOP was determined for average ‘A’ climate conditions and for a bivalent temperature of  $-10\text{ }^{\circ}\text{C}$ . The SCOP was calculated considering a heat pump operating with fixed or variable outlet temperature and with the compressor running at fixed or variable speed, in order to compare the results between these different types of technologies. The main conclusions are the following:

- For outdoor temperatures between  $-10\text{ }^{\circ}\text{C}$  and  $2\text{ }^{\circ}\text{C}$ , the heat pump heating capacity could be adjusted to the heating load by varying the compressor speed.
- For outdoor temperatures above  $2\text{ }^{\circ}\text{C}$ , the power supplied by the heat pump was always greater than the heating load, so the unit would need to perform on/off cycles to adjust its power to the heating load.
- For the heat pump with fixed outlet temperature, as the compressor speed decreased to meet the heating load, the COP increased until it reached a maximum value. A further decrease of the compressor speed caused a decrease in the COP.
- For the heat pump with variable outlet temperature, both the compressor speed and the supply water temperature decreased with an increase of the outdoor temperature (heating load reduction). Results showed that for the heat pump tested the COP always increased with a heat load reduction.
- For the four options tested, the heat pump with variable compressor speed and variable outlet temperature showed the highest SCOP value, around 26% higher than for the fixed compressor speed and fixed outlet temperature option.

**Author Contributions:** Conceptualization, J.S., I.O., F.C., E.Á. and J.M.S.; methodology, I.O. and J.S.; investigation, J.S., I.O., F.C., E.Á. and J.M.S.; resources, J.S. and F.C.; data curation, J.S.; writing—original draft preparation, J.S., I.O., F.C., E.Á. and J.M.S.; writing—review and editing, J.S., I.O., F.C., E.Á. and J.M.S.; funding acquisition, J.S., F.C., E.Á. and J.M.S. All authors have read and agreed to the published version of the manuscript.

**Funding:** This research was funded by the Spanish ‘Agencia Estatal de Investigación’, within the ‘Programa Estatal de I+D+i Orientada a los Retos de la Sociedad del Plan Estatal de Investigación Científica y Técnica y de Innovación 2017–2020’, grant number PID2019-104762RB-I00/AEI/10.13039/501100011033.

**Data Availability Statement:** The data presented in this study are available on request from the corresponding author.

**Conflicts of Interest:** The authors declare no conflict of interest.

## References

1. Eurostat—Database 2020. Available online: <https://ec.europa.eu/eurostat/en/web/main/data/database> (accessed on 21 December 2021).
2. Gaur, A.S.; Fitiwi, D.Z.; Curtis, J. Heat pumps and our low-carbon future: A comprehensive review. *Energy Res. Soc. Sci.* **2021**, *71*, 101764. [CrossRef]
3. In, S.; Cho, K.; Lim, B.; Lee, C. Partial load performance test of residential heat pump system with low-GWP refrigerants. *Appl. Therm. Eng.* **2015**, *85*, 179–187. [CrossRef]
4. Devcioğlu, A.G. Seasonal performance assessment of refrigerants with low GWP as substitutes for R410A in heat pump air conditioning devices. *Appl. Therm. Eng.* **2017**, *125*, 401–411. [CrossRef]
5. Dongellini, M.; Naldi, C.; Morini, G.L. Seasonal performance evaluation of electric air-to-water heat pump systems. *Appl. Therm. Eng.* **2015**, *90*, 1072–1081. [CrossRef]

6. Dongellini, M.; Naldi, C.; Morini, G.L. Annual performances of reversible air source heat pumps for space conditioning. *Energy Procedia* **2015**, *78*, 1123–1228. [[CrossRef](#)]
7. Abid, M.; Hewitt, N.; Huang, M.-J.; Wilson, C.; Cotter, D. Domestic retrofit assessment of the heat pump system considering the impact of heat supply temperature and operating mode of control—A case study. *Sustainability* **2021**, *13*, 10857. [[CrossRef](#)]
8. Mouzeviris, G.A.; Papakostas, K.T. Air-to-water heat pumps: The impact of climate, compressor technology, water output temperature and sizing on the seasonal coefficient of performance for heating. *IOP Conf. Ser. Mater. Sci. Eng.* **2020**, *997*, 012150. [[CrossRef](#)]
9. Kudela, L.; Špiláček, M.; Pospíšil, J. Influence of control strategy on seasonal coefficient of performance for a heat pump with low-temperature heat storage in the geographical conditions of Central Europe. *Energy* **2021**, *234*, 121276. [[CrossRef](#)]
10. Busato, F.; Lazzarin, R.M.; Noro, M. Energy and economic analyses of different heat pump systems for space heating. *Int. J. Low-Carbon Technol.* **2012**, *7*, 104–112. [[CrossRef](#)]
11. European Union. Commission Regulation (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. *Off. J. Eur. Union* **2013**, *239*, 136–161.
12. *Standard EN 14825:2018*; Air Conditioners, Liquid Chilling Packages and Heat Pumps, with Electrically Driven Compressors, for Space Heating and Cooling—Testing and Rating at Part Load Conditions and Calculation of Seasonal Performance. European Committee for Standardization: Brussels, Belgium, 2018.
13. Sieres, J.; Ortega, I.; Cerdeira, F.; Álvarez, E. Drop-in performance of the low-GWP alternative refrigerants R452B and R454B in an R410A liquid-to-water heat pump. *Appl. Therm. Eng.* **2021**, *182*, 116049. [[CrossRef](#)]
14. Sieres, J.; Ortega, I.; Cerdeira, F.; Álvarez, E.; Santos, J.M. Calculation of the seasonal efficiency of a brine-to-water heat pumps according to ecodesign standards. In Proceedings of the CYTEF 2022—XI Congreso Ibérico | IX Congreso Iberoamericano de Ciencias y Técnicas del Frío, Cartagena, Spain, 17–19 April 2022. (In Spanish).
15. *Standard EN 14511-2:2018*; Air Conditioners, Liquid Chilling Packages and Heat Pumps for Space Heating and Cooling and Process Chillers, with Electrically Driven Compressors—Part 2: Test Conditions. European Committee for Standardization: Brussels, Belgium, 2018.
16. *Standard EN 14511-3:2018*; Air Conditioners, Liquid Chilling Packages and Heat Pumps for Space Heating and Cooling and Process Chillers, with Electrically Driven Compressors—Part 3: Test Methods. European Committee for Standardization: Brussels, Belgium, 2018.
17. European Union. Commission Delegated Regulation (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. *Off. J. Eur. Union* **2013**, *239*, 1–82.